



**TOWN OF FORT MILL
FIRE MARSHAL'S OFFICE**

MOBILE FOOD VEHICLE INSPECTION CHECKLIST

Permit No.: _____
Date: _____ Time of Inspection: _____
Location of Inspection: **Fort Mill Fire Department, Station 1, 121 Tom Hall Street, Fort Mill, SC 29715**
Vehicle Representative: _____
Contact Number: _____ Email: _____
License Plate No.: _____

FIRE EXTINGUISHERS:

- | | | | | |
|---|--|--|-------------------------------------|-------------------------------------|
| <input type="checkbox"/> 2A10BC | <input type="checkbox"/> 3A40BC | <input type="checkbox"/> Inspected per NFPA 10 | <input type="checkbox"/> Mounted | <input type="checkbox"/> Accessible |
| <input type="checkbox"/> Class K Extinguisher | <input type="checkbox"/> Inspected per NFPA 10 | <input type="checkbox"/> Mounted | <input type="checkbox"/> Accessible | |

LPG (Propane):

- L.P. Gas containers shall be located and secured on the exterior of vehicle.
Not to be located on roof, inside passenger compartment, or extend further than the rear bumper and shall be protected from vehicle collision.
- "NO SMOKING" sign posted with a minimum of 4-inch lettering above propane bottle.
- Hose used to pipe L.P. Gas must be Underwriter Laboratories (UL) or FM listed (marked 350 psi working pressure)
- Couplings, fittings, and other deices meet UL or FM requirements.
- LPG tanks are to be located outside the vehicle with a minimum 5 feet from primary means of egress.

TYPE II HOOD / FIRE SUPPRESSION SYSTEM:

- Type II Hood cleaned with record of cleaning verified.
- Fire Suppression System serviced with record of service verified.

GENERATOR:

- Refueling of generators to be performed in an approved location not less than 20 feet from vehicle.
- Fuel to be stored away from vehicle, no less than 20 feet, or in approved flammable liquid safety container.
- Storage is in an approved location (secured from movement).
- Generators shall be grounded in an approved method.
- Generators shall not be refueled in areas occupied by the public.
- Generators shall be caged or fenced off to prevent public access in approved manner.
- A minimum 2A10BC extinguisher shall be located a minimum of 20 feet from generator while refueling.

GENERAL FIRE SAFETY:

- Installation of electrical equipment shall comply with the Electrical Codes NFPA 70 and NEC.
- Aisle-way on interior of vehicle kept clear of storage and combustibile materials.
- Exit door latch mechanism(s) shall be operable by hand.

Approved Disapproved If Approved Permit Sticker Number: _____

Inspected by: _____ Date: _____

Re-Inspection Re-Scheduled for Date: _____

